

Report For: City of Prince George
 Received: 11/21/2021 13:48
 Report ID: 21J2885
 Report Name: 21J2885_FINAL_WaterTrax_21_Nov_21_1347.txt

Sample ID: 21J2885-01
 Water System: Core Water System
 Source: PW 601 Well
 Facility: PW 601 Well Pumphouse
 Sampling Pt: PW 601 Pumphouse raw water (PW601-1-SR, DBB1)
 Comment: Generated by File Transfer
 Sampled: 10/20/2021 12:00

INORGANIC		Criteria & Type		Status
Aluminum (dissolved)	< 0.0050 mg/L			Final
Aluminum (total)	< 0.0050 mg/L	<=0.1	Operational - Conventional	Final
Ammonia (total, as N)	< 0.050 mg/L			Final
Antimony (dissolved)	< 0.00020 mg/L			Final
Antimony (total)	0.00023 mg/L	<=0.006	MAC	Final
Arsenic (dissolved)	0.00055 mg/L			Final
Arsenic (total)	0.00053 mg/L		Current Level	Final
Barium (dissolved)	0.0196 mg/L			Final
Barium (total)	0.0189 mg/L	<=2	MAC	Final
Beryllium (dissolved)	< 0.00010 mg/L			Final
Beryllium (total)	< 0.00010 mg/L			Final
Bismuth (dissolved)	< 0.00010 mg/L			Final
Bismuth (total)	< 0.00010 mg/L			Final
Boron (dissolved)	< 0.0500 mg/L			Final
Boron (total)	< 0.0500 mg/L	<=5	MAC	Final
Bromide	< 0.10 mg/L			Final
Cadmium (dissolved)	0.000012 mg/L			Final
Cadmium (total)	0.000014 mg/L	<=0.005	MAC	Final
Calcium (dissolved)	29.4 mg/L			Final
Calcium (total)	33.1 mg/L			Final
Chloride	5.12 mg/L	<=250	AO	Final
Chromium (extractable)	< 0.00050 mg/L			Final
Chromium (total)	< 0.00050 mg/L	<=0.05	MAC	Final
Cobalt (dissolved)	< 0.00010 mg/L			Final
Cobalt (total)	< 0.00010 mg/L			Final
Copper (extractable)	0.00085 mg/L			Final
Copper (total)	0.00087 mg/L	<=1	AO	Final
Fluoride	< 0.10 mg/L	<=1.5	MAC	Final
Iron (dissolved)	< 0.010 mg/L			Final
Iron (total)	< 0.010 mg/L	<=0.3	AO	Final
Lead (dissolved)	< 0.00020 mg/L			Final



Laboratory Report

Caro Analytical Services

Report Name: 21J2885_FINAL_WaterTrax_21_Nov_21_1347.txt

Sample ID: 21J2885-01 (continued)
Water System: Core Water System
Source: PW 601 Well
Facility: PW 601 Well Pumphouse
Sampling Pt: PW 601 Pumphouse raw water (PW601-1-SR, DBB1)
Comment: Generated by File Transfer
Sampled: 10/20/2021 12:00

INORGANIC		Criteria & Type	Status
Lead (total)	< 0.00020 mg/L	<=0.005 MAC	Final
Lithium (dissolved)	0.00087 mg/L		Final
Lithium (total)	0.00107 mg/L		Final
Magnesium (dissolved)	9.16 mg/L		Final
Magnesium (total)	9.34 mg/L		Final
Manganese (dissolved)	0.00982 mg/L		Final
Manganese (total)	0.00926 mg/L	<=0.02 AO	Final
Mercury (dissolved)	< 0.000010 mg/L		Final
Mercury (total)	< 0.000010 mg/L	<=0.001 MAC	Final
Molybdenum (dissolved)	0.00107 mg/L		Final
Molybdenum (total)	0.00095 mg/L		Final
Nickel (dissolved)	0.00066 mg/L		Final
Nickel (total)	< 0.00040 mg/L		Final
Nitrate (as N)	0.060 mg/L		Final
Nitrate + Nitrite (as N)	0.0605 mg/L		Final
Nitrite (as N)	< 0.010 mg/L		Final
o-Phosphate (as P)	< 0.0050 mg/L		Final
Phosphorus (total dissolved)	< 0.050 mg/L		Final
Phosphorus (total)	< 0.050 mg/L		Final
Potassium (dissolved)	1.32 mg/L		Final
Potassium (total)	1.33 mg/L		Final
Selenium (dissolved)	0.00087 mg/L		Final
Selenium (total)	0.00076 mg/L	<=0.05 MAC	Final
Silicon (dissolved, as Si)	6.0 mg/L		Final
Silicon (total, as Si)	6.4 mg/L		Final
Silver (dissolved)	< 0.000050 mg/L		Final
Silver (total)	< 0.000050 mg/L		Final
Sodium (dissolved)	3.61 mg/L		Final
Sodium (total)	3.67 mg/L	<=200 AO	Final
Strontium (dissolved)	0.120 mg/L		Final
Strontium (total)	0.135 mg/L		Final
Sulfur (dissolved)	< 3.0 mg/L		Final
Sulfur (total)	< 3.0 mg/L		Final
Sulphate	7.9 mg/L	<=500 AO	Final
Tellurium (dissolved)	< 0.00050 mg/L		Final
Tellurium (total)	< 0.00050 mg/L		Final



Laboratory Report**Caro Analytical Services**

Report Name: 21J2885_FINAL_WaterTrax_21_Nov_21_1347.txt

Sample ID: 21J2885-01 (continued)
Water System: Core Water System
Source: PW 601 Well
Facility: PW 601 Well Pumphouse
Sampling Pt: PW 601 Pumphouse raw water (PW601-1-SR, DBB1)
Comment: Generated by File Transfer
Sampled: 10/20/2021 12:00

INORGANIC		Criteria & Type	Status
Thallium (dissolved)	< 0.000020 mg/L		Final
Thallium (total)	< 0.000020 mg/L		Final
Thorium (dissolved)	< 0.00010 mg/L		Final
Thorium (total)	< 0.00010 mg/L		Final
Tin (dissolved)	< 0.00020 mg/L		Final
Tin (total)	< 0.00020 mg/L		Final
Titanium (dissolved)	< 0.0050 mg/L		Final
Titanium (total)	< 0.0050 mg/L		Final
Tungsten (dissolved)	< 0.0010 mg/L		Final
Tungsten (total)	< 0.0010 mg/L		Final
Uranium (dissolved)	0.000223 mg/L		Final
Vanadium (dissolved)	< 0.0010 mg/L		Final
Vanadium (total)	0.0011 mg/L		Final
Zinc (dissolved)	< 0.0040 mg/L		Final
Zinc (total)	< 0.0040 mg/L	<=5 AO	Final
Zirconium (dissolved)	< 0.00010 mg/L		Final
Zirconium (total)	< 0.00010 mg/L		Final

MICROORGANISMS		Criteria & Type	Status
Escherichia coli / E. coli (counts)	< 1 CFU/100ml	<=0,OG Microbiological standard	Final
Fecal (thermal tolerant) Coliforms (counts)	< 1 CFU/100ml	<=0 Microbiological Standard	Final
Total Coliforms (counts)	< 1 CFU/100ml	<=0,OG User-Defined	Final

ORGANIC		Criteria & Type	Status
Adsorbable Organic Halides / AOX	< 50 ug/L		Final
Bromodichloromethane (dichlorobromomethane)	< 0.0010 mg/L	<=0.1 IMAC for TTHM expressed as a running annual average	Final
Bromoform	< 0.0010 mg/L	<=0.1 IMAC for TTHM expressed as a running annual average	Final
Chloroform	< 0.0010 mg/L	<=0.1 Standard for TTHM expressed as a running annual average	Final
Dibromochloromethane (Chlorodibromomethane)	< 0.0010 mg/L	<=0.1 IMAC for TTHM expressed as a running annual average	Final
Nitrogen (Total) (total)	0.0605 mg/L		Final
Total Kjeldahl Nitrogen / TKN	< 0.050 mg/L		Final



Laboratory Report

Report Name: 21J2885_FINAL_WaterTrax_21_Nov_21_1347.txt

Sample ID: 21J2885-01 (continued)
Water System: Core Water System
Source: PW 601 Well
Facility: PW 601 Well Pumphouse
Sampling Pt: PW 601 Pumphouse raw water (PW601-1-SR, DBB1)
Comment: Generated by File Transfer
Sampled: 10/20/2021 12:00

ORGANIC		Criteria & Type	Status
Total Trihalomethanes / TTHM	< 0.00400 mg/L	<=0.1 IMAC based on running annual average	Final
PHYSICAL		Criteria & Type	Status
Alkalinity (bicarbonate, as CaCO3)	122 mg/L		Final
Alkalinity (carbonate, as CaCO3)	< 1.0 mg/L		Final
Alkalinity (hydroxide, as CaCO3)	< 1.0 mg/L		Final
Alkalinity (phenolphthalein, as CaCO3)	< 1.0 mg/L		Final
Alkalinity (total, as CaCO3)	122 mg/L		Final
Hardness (total, as CaCO3)	111 mg/L		Final
Hardness (total, as CaCO3)	121 mg/L		Final
Total Suspended Solids / TSS	< 2.0 mg/L		Final
RADIONUCLIDES		Criteria & Type	Status
Uranium (total)	0.000226 mg/L	<=0.02 MAC	Final

Result Legend

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no, TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment
< means less than lower detection limit shown
> means greater than upper detection limit shown
« means detected & less than number shown
» means detected & greater than number shown
*** Indicates Criteria is exceeded**

