Caro Analytical Services

Report For: City of Prince George Received: 05/17/2022 17:00

Report ID: 22D3070

Report Name: 22D3070_FINAL_WaterTrax_17_May_22_0825.txt

Sample ID: 22D3070-01

Water System: Core Water System

Source: PW 624 and PW 621 Wells Facility: PW 624 Well Pumphouse

Sampling Pt: PW 624 Pumphouse Well 1 raw water (PW624-1-SR, DBA5)

Comment: Generated by File Transfer

Sampled: 04/26/2022 12:45

INORGANIC			Criteria & Type		ре	Status
	Aluminum (dissolved)	< 0.0050	mg/L			Final
	Aluminum (total)	< 0.0050	mg/L	<=0.1	Operational - Conventional	Final
	Ammonia (total, as N)	< 0.050	mg/L			Final
	Antimony (dissolved)	< 0.00020	mg/L			Final
	Antimony (total)	< 0.00020	mg/L	<=0.006	MAC	Final
	Arsenic (dissolved)	0.00096	mg/L			Final
	Arsenic (total)	0.00095	mg/L		Current Level	Final
	Barium (dissolved)	0.0523	mg/L			Final
	Barium (total)	0.0466	mg/L	<=2	MAC	Final
	Beryllium (dissolved)	< 0.00010	mg/L			Final
	Beryllium (total)	< 0.00010	mg/L			Final
	Bismuth (dissolved)	< 0.00010	mg/L			Final
	Bismuth (total)	< 0.00010	mg/L			Final
	Boron (dissolved)	< 0.0500	mg/L			Final
	Boron (total)	< 0.0500	mg/L	<=5	MAC	Final
	Bromide	< 0.10	mg/L			Final
	Cadmium (dissolved)	0.000010	mg/L			Final
	Cadmium (total)	0.000013	mg/L	<=0.005	MAC	Final
	Calcium (dissolved)	49.7	mg/L			Final
	Calcium (total)	47.6	mg/L			Final
	Chloride	21.6	mg/L	<=250	AO	Final
	Chromium (extractable)	< 0.00050	mg/L			Final
	Chromium (total)	< 0.00050	mg/L	<=0.05	MAC	Final
	Cobalt (dissolved)	< 0.00010	mg/L			Final
	Cobalt (total)	< 0.00010	mg/L			Final
	Copper (extractable)	0.0207	mg/L			Final
	Copper (total)	0.0207	mg/L	<=1	AO	Final
	Fluoride	< 0.10	mg/L	<=1.5	MAC	Final
	Iron (dissolved)	< 0.010	mg/L			Final
	Iron (total)	< 0.010	mg/L	<=0.3	AO	Final
	Lead (dissolved)	0.00088	mg/L			Final



Report Name: 22D3070_FINAL_WaterTrax_17_May_22_0825.txt

Sample ID: 22D3070-01 (continued)

Water System: Core Water System

Source: PW 624 and PW 621 Wells Facility: PW 624 Well Pumphouse

Sampling Pt: PW 624 Pumphouse Well 1 raw water (PW624-1-SR, DBA5)

Comment: Generated by File Transfer

Sampled: 04/26/2022 12:45

INORGANIC		Criteria & Type			
Lead (total)	0.00102	mg/L	<=0.005	MAC	Final
Lithium (dissolved)	0.00308	mg/L			Final
Lithium (total)	0.00294	mg/L			Final
Magnesium (dissolved)	16.7	mg/L			Final
Magnesium (total)	15.0	mg/L			Final
Manganese (dissolved)	0.0195	mg/L			Final
Manganese (total)	0.0191	mg/L	<=0.02	AO	Final
Mercury (dissolved)	< 0.000010	mg/L			Final
Mercury (total)	< 0.000010	mg/L	<=0.001	MAC	Final
Molybdenum (dissolved)	0.00173	mg/L			Final
Molybdenum (total)	0.00155	mg/L			Final
Nickel (dissolved)	< 0.00040	mg/L			Final
Nickel (total)	< 0.00040	mg/L			Final
Nitrate (as N)	0.061	mg/L			Final
Nitrate + Nitrite (as N)	0.0607	mg/L			Final
Nitrite (as N)	< 0.010	mg/L			Final
o-Phosphate (as P)	< 0.0050	mg/L			Final
Phosphorus (total dissolved)	< 0.050	mg/L			Final
Phosphorus (total)	< 0.050	mg/L			Final
Potassium (dissolved)	2.86	mg/L			Final
Potassium (total)	2.54	mg/L			Final
Selenium (dissolved)	0.00063	mg/L			Final
Selenium (total)	0.00063	mg/L	<=0.05	MAC	Final
Silicon (dissolved, as Si)	6.5	mg/L			Final
Silicon (total, as Si)	6.4	mg/L			Final
Silver (dissolved)	< 0.000050	mg/L			Final
Silver (total)	< 0.000050	mg/L			Final
Sodium (dissolved)	7.71	mg/L			Final
Sodium (total)	7.15	mg/L	<=200	AO	Final
Strontium (dissolved)	0.370	mg/L			Final
Strontium (total)	0.334	mg/L			Final
Sulfur (dissolved)	4.7	mg/L			Final
Sulfur (total)	5.1	mg/L			Final
Sulphate	13.8	mg/L	<=500	AO	Final
Tellurium (dissolved)	< 0.00050	mg/L			Final
Tellurium (total)	< 0.00050	mg/L			Final



Report Name: 22D3070_FINAL_WaterTrax_17_May_22_0825.txt

Sample ID: 22D3070-01 (continued)

Water System: Core Water System

Source: PW 624 and PW 621 Wells Facility: PW 624 Well Pumphouse

Sampling Pt: PW 624 Pumphouse Well 1 raw water (PW624-1-SR, DBA5)

Comment: Generated by File Transfer

Sampled: 04/26/2022 12:45

INORGANIC			Criteria & T	уре	Status
Thallium (dissolved)	< 0.000020	mg/L			Final
Thallium (total)	< 0.000020	mg/L			Final
Thorium (dissolved)	< 0.00010	mg/L			Final
Thorium (total)	< 0.00010	mg/L			Final
Tin (dissolved)	< 0.00020	mg/L			Final
Tin (total)	< 0.00004	mg/L			Final
Titanium (dissolved)	< 0.0050	mg/L			Final
Titanium (total)	< 0.0050	mg/L			Final
Tungsten (dissolved)	< 0.0010	mg/L			Final
Tungsten (total)	< 0.0002	mg/L			Final
Uranium (dissolved)	0.00183	mg/L			Final
Vanadium (dissolved)	< 0.0010	mg/L			Final
Vanadium (total)	< 0.0010	mg/L			Final
Zinc (dissolved)	0.0407	mg/L			Final
Zinc (total)	0.0402	mg/L	<=5	AO	Final
Zirconium (dissolved)	< 0.00010	mg/L			Final
Zirconium (total)	< 0.00010	mg/L			Final
MICROORGANISMS			Criteria & T	ype	Status
Escherichia coli / E. coli (MPN)	< 1	MPN/100ml	<=0,P	Microbiological standard	Final
Fecal (thermal tolerant) Coliforms (MPN / PA)	< 1	MPN/100ml			Final
Total Coliforms (MPN)	< 1	MPN/100ml	<=0,P	User-Defined	Final
ORGANIC			Criteria & T	уре	Status
Adsorbable Organic Halides / AOX	< 50	ug/L			Final
Bromodichloromethane (dichlorobromomethane)	< 0.0010	mg/L	<=0.1	IMAC for TTHM expressed as a running annual average	Final
Bromoform	< 0.0010	mg/L	<=0.1	IMAC for TTHM expressed as a running annual average	Final
Chloroform	< 0.0010	mg/L	<=0.1	Standard for TTHM expresse as a running annual average	Final d
Dibromochloromethane (Chlorodibromomethane)	< 0.0010	mg/L	<=0.1	IMAC for TTHM expressed as a running annual average	Final
Nitrogen (Total) (total)	0.254	mg/L			Final
Total Kjeldahl Nitrogen / TKN	0.193	mg/L			Final
Report created on 06/20/2022 08:38:53					page 3 of 5



Caro Analytical Services

Report Name: 22D3070_FINAL_WaterTrax_17_May_22_0825.txt

Sample ID: 22D3070-01 (continued)

Water System: Core Water System

PW 624 and PW 621 Wells Source: Facility: PW 624 Well Pumphouse

Sampling Pt: PW 624 Pumphouse Well 1 raw water (PW624-1-SR, DBA5)

Comment: Generated by File Transfer

04/26/2022 12:45 Sampled:

ORGANIC			Criteria	riteria & Type	
Total Trihalomethanes / TTHM	< 0.00400	mg/L	<=0.1	IMAC based running annu average	
PHYSICAL			Criteria	& Type	Status
Alkalinity (bicarbonate, as CaCO3)	176	mg/L			Final
Alkalinity (carbonate, as CaCO3)	< 1.0	mg/L			Final
Alkalinity (hydroxide, as CaCO3)	< 1.0	mg/L			Final
Alkalinity (phenolphthalein, as CaCO3)	< 1.0	mg/L			Final
Alkalinity (total, as CaCO3)	176	mg/L			Final
Hardness (total, as CaCO3)	193	mg/L			Final
Hardness (total, as CaCO3)	181	mg/L			Final
Total Suspended Solids / TSS	< 2.0	mg/L			Final
RADIONUCLIDES			Criteria	& Type	Status
Uranium (total)	0.00192	mg/L	<=0.02	MAC	Final

Result Legend

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no, TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

- < means less than lower detection limit shown
- > means greater than upper detection limit shown
- « means detected & less than number shown
- » means detected & greater than number shown

^{*} Indicates Criteria is exceeded

