

Report For: City of Prince George
 Received: 05/17/2022 17:00
 Report ID: 22D3027
 Report Name: 22D3027_FINAL_WaterTrax_17_May_22_0826.txt

Sample ID: 22D3027-01
 Water System: Upper Hart Water System
 Source: PW 660 WELL
 Facility: PW 660 Well Pumphouse
 Sampling Pt: PW-660 Pumphouse Raw Water (PW660-1-SR, 14C95)
 Comment: Generated by File Transfer
 Sampled: 04/25/2022 13:15

INORGANIC			Criteria & Type	Status
Aluminum (dissolved)	< 0.0050	mg/L		Final
Aluminum (total)	< 0.0050	mg/L	<=0.1 Operational - Conventional	Final
Ammonia (total, as N)	< 0.050	mg/L		Final
Antimony (dissolved)	< 0.00020	mg/L		Final
Antimony (total)	< 0.00020	mg/L	<=0.006 MAC	Final
Arsenic (dissolved)	< 0.00050	mg/L		Final
Arsenic (total)	< 0.00050	mg/L	Current Level	Final
Barium (dissolved)	0.0342	mg/L		Final
Barium (total)	0.0314	mg/L	<=2 MAC	Final
Beryllium (dissolved)	< 0.00010	mg/L		Final
Beryllium (total)	< 0.00010	mg/L		Final
Bismuth (dissolved)	< 0.00010	mg/L		Final
Bismuth (total)	< 0.00010	mg/L		Final
Boron (dissolved)	< 0.0500	mg/L		Final
Boron (total)	< 0.0500	mg/L	<=5 MAC	Final
Bromide	< 0.10	mg/L		Final
Cadmium (dissolved)	0.000021	mg/L		Final
Cadmium (total)	0.000019	mg/L	<=0.005 MAC	Final
Calcium (dissolved)	24.9	mg/L		Final
Calcium (total)	24.9	mg/L		Final
Chloride	6.79	mg/L	<=250 AO	Final
Chromium (extractable)	< 0.00050	mg/L		Final
Chromium (total)	< 0.00050	mg/L	<=0.05 MAC	Final
Cobalt (dissolved)	< 0.00010	mg/L		Final
Cobalt (total)	< 0.00010	mg/L		Final
Copper (extractable)	0.00929	mg/L		Final
Copper (total)	0.00925	mg/L	<=1 AO	Final
Fluoride	< 0.10	mg/L	<=1.5 MAC	Final
Iron (dissolved)	< 0.010	mg/L		Final
Iron (total)	< 0.010	mg/L	<=0.3 AO	Final
Lead (dissolved)	0.00237	mg/L		Final



Laboratory Report

Caro Analytical Services

Report Name: 22D3027_FINAL_WaterTrax_17_May_22_0826.txt

Sample ID: 22D3027-01 (continued)
Water System: Upper Hart Water System
Source: PW 660 WELL
Facility: PW 660 Well Pumphouse
Sampling Pt: PW-660 Pumphouse Raw Water (PW660-1-SR, 14C95)
Comment: Generated by File Transfer
Sampled: 04/25/2022 13:15

INORGANIC		Criteria & Type	Status
Lead (total)	0.00256 mg/L	<=0.005 MAC	Final
Lithium (dissolved)	< 0.00010 mg/L		Final
Lithium (total)	0.00011 mg/L		Final
Magnesium (dissolved)	8.37 mg/L		Final
Magnesium (total)	7.94 mg/L		Final
Manganese (dissolved)	0.00705 mg/L		Final
Manganese (total)	0.00698 mg/L	<=0.02 AO	Final
Mercury (dissolved)	< 0.000010 mg/L		Final
Mercury (total)	< 0.000010 mg/L	<=0.001 MAC	Final
Molybdenum (dissolved)	0.00163 mg/L		Final
Molybdenum (total)	0.00181 mg/L		Final
Nickel (dissolved)	0.00103 mg/L		Final
Nickel (total)	0.00131 mg/L		Final
Nitrate (as N)	0.054 mg/L		Final
Nitrate + Nitrite (as N)	0.0539 mg/L		Final
Nitrite (as N)	< 0.010 mg/L		Final
o-Phosphate (as P)	< 0.0050 mg/L		Final
Phosphorus (total dissolved)	< 0.050 mg/L		Final
Phosphorus (total)	< 0.050 mg/L		Final
Potassium (dissolved)	1.13 mg/L		Final
Potassium (total)	1.07 mg/L		Final
Selenium (dissolved)	< 0.00050 mg/L		Final
Selenium (total)	< 0.00050 mg/L	<=0.05 MAC	Final
Silicon (dissolved, as Si)	4.8 mg/L		Final
Silicon (total, as Si)	4.8 mg/L		Final
Silver (dissolved)	< 0.000050 mg/L		Final
Silver (total)	< 0.000050 mg/L		Final
Sodium (dissolved)	4.85 mg/L		Final
Sodium (total)	4.85 mg/L	<=200 AO	Final
Strontium (dissolved)	0.126 mg/L		Final
Strontium (total)	0.121 mg/L		Final
Sulfur (dissolved)	< 3.0 mg/L		Final
Sulfur (total)	< 3.0 mg/L		Final
Sulphate	8.0 mg/L	<=500 AO	Final
Tellurium (dissolved)	< 0.00050 mg/L		Final
Tellurium (total)	< 0.00050 mg/L		Final



Laboratory Report

Report Name: 22D3027_FINAL_WaterTrax_17_May_22_0826.txt

Sample ID: 22D3027-01 (continued)
Water System: Upper Hart Water System
Source: PW 660 WELL
Facility: PW 660 Well Pumphouse
Sampling Pt: PW-660 Pumphouse Raw Water (PW660-1-SR, 14C95)
Comment: Generated by File Transfer
Sampled: 04/25/2022 13:15

INORGANIC		Criteria & Type	Status
Thallium (dissolved)	< 0.000020 mg/L		Final
Thallium (total)	< 0.000020 mg/L		Final
Thorium (dissolved)	< 0.00010 mg/L		Final
Thorium (total)	< 0.00010 mg/L		Final
Tin (dissolved)	< 0.00020 mg/L		Final
Tin (total)	< 0.00004 mg/L		Final
Titanium (dissolved)	< 0.0050 mg/L		Final
Titanium (total)	< 0.0050 mg/L		Final
Tungsten (dissolved)	< 0.0010 mg/L		Final
Tungsten (total)	< 0.0002 mg/L		Final
Uranium (dissolved)	0.000204 mg/L		Final
Vanadium (dissolved)	< 0.0010 mg/L		Final
Vanadium (total)	< 0.0010 mg/L		Final
Zinc (dissolved)	0.0052 mg/L		Final
Zinc (total)	0.0076 mg/L	<=5 AO	Final
Zirconium (dissolved)	< 0.00010 mg/L		Final
Zirconium (total)	< 0.00010 mg/L		Final
MICROORGANISMS		Criteria & Type	Status
Escherichia coli / E. coli (MPN)	< 1 MPN/100ml	<=0,P Microbiological standard	Final
Fecal (thermal tolerant) Coliforms (MPN / PA)	< 1 MPN/100ml		Final
Total Coliforms (MPN)	< 1 MPN/100ml	<=0,P User-Defined	Final
ORGANIC		Criteria & Type	Status
Adsorbable Organic Halides / AOX	< 50 ug/L		Final
Bromodichloromethane (dichlorobromomethane)	< 0.0010 mg/L	<=0.1 IMAC for TTHM expressed as a running annual average	Final
Bromoform	< 0.0010 mg/L	<=0.1 IMAC for TTHM expressed as a running annual average	Final
Chloroform	< 0.0010 mg/L	<=0.1 Standard for TTHM expressed as a running annual average	Final
Dibromochloromethane (Chlorodibromomethane)	< 0.0010 mg/L	<=0.1 IMAC for TTHM expressed as a running annual average	Final
Nitrogen (Total) (total)	0.0539 mg/L		Final
Total Kjeldahl Nitrogen / TKN	< 0.050 mg/L		Final



Laboratory Report

Caro Analytical Services

Report Name: 22D3027_FINAL_WaterTrax_17_May_22_0826.txt

Sample ID: 22D3027-01 (continued)
Water System: Upper Hart Water System
Source: PW 660 WELL
Facility: PW 660 Well Pumphouse
Sampling Pt: PW-660 Pumphouse Raw Water (PW660-1-SR, 14C95)
Comment: Generated by File Transfer
Sampled: 04/25/2022 13:15

ORGANIC		Criteria & Type	Status
Total Trihalomethanes / TTHM	< 0.00400 mg/L	<=0.1 IMAC based on running annual average	Final
PHYSICAL		Criteria & Type	Status
Alkalinity (bicarbonate, as CaCO3)	104 mg/L		Final
Alkalinity (carbonate, as CaCO3)	< 1.0 mg/L		Final
Alkalinity (hydroxide, as CaCO3)	< 1.0 mg/L		Final
Alkalinity (phenolphthalein, as CaCO3)	< 1.0 mg/L		Final
Alkalinity (total, as CaCO3)	104 mg/L		Final
Hardness (total, as CaCO3)	96.8 mg/L		Final
Hardness (total, as CaCO3)	94.9 mg/L		Final
Total Suspended Solids / TSS	< 2.0 mg/L		Final
RADIONUCLIDES		Criteria & Type	Status
Uranium (total)	0.000204 mg/L	<=0.02 MAC	Final

Result Legend

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no,
TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment
< means less than lower detection limit shown

> means greater than upper detection limit shown

« means detected & less than number shown

» means detected & greater than number shown

* Indicates Criteria is exceeded

