

Report For: City of Prince George  
 Received: 09/25/2020 13:41  
 Report ID: 0041739  
 Report Name: 0041739\_FINAL\_WaterTrax\_25\_Sep\_20\_1334.txt

**Sample ID: 0041739-01**  
 Water System: Core Water System  
 Source: PW 624 and PW 621 Wells  
 Facility: PW 624 Well Pumphouse  
 Sampling Pt: PW 624 Pumphouse Well 1 raw water (PW624-1-SR, DBA5)  
 Comment: Generated by File Transfer  
 Sampled: 04/22/2020 10:00

INORGANIC		Criteria & Type	Status
Aluminum (dissolved)	< 0.0050 mg/L		Final
Aluminum (total)	< 0.0050 mg/L	<=0.1 Operational - Conventional	Final
Ammonia (total, as N)	< 0.050 mg/L		Final
Antimony (dissolved)	< 0.00020 mg/L		Final
Antimony (total)	< 0.00020 mg/L	<=0.006 MAC	Final
Arsenic (dissolved)	0.00132 mg/L		Final
Arsenic (total)	0.00144 mg/L	Current Level	Final
Barium (dissolved)	0.0442 mg/L		Final
Barium (total)	0.0479 mg/L	<=2 MAC	Final
Beryllium (dissolved)	< 0.00010 mg/L		Final
Beryllium (total)	< 0.00010 mg/L		Final
Bismuth (dissolved)	< 0.00010 mg/L		Final
Bismuth (total)	< 0.00010 mg/L		Final
Boron (dissolved)	0.0218 mg/L		Final
Boron (total)	0.0224 mg/L	<=5 MAC	Final
Bromide	< 0.10 mg/L		Final
Cadmium (dissolved)	0.000017 mg/L		Final
Cadmium (total)	0.000030 mg/L	<=0.005 MAC	Final
Calcium (dissolved)	40.4 mg/L		Final
Calcium (total)	42.0 mg/L		Final
Chloride	13.4 mg/L	<=250 AO	Final
Chromium (dissolved)	< 0.00050 mg/L		Final
Chromium (total)	< 0.00050 mg/L	<=0.05 MAC	Final
Cobalt (dissolved)	< 0.00010 mg/L		Final
Cobalt (total)	< 0.00010 mg/L		Final
Copper (dissolved)	0.0229 mg/L		Final
Copper (total)	0.0169 mg/L	<=1 AO	Final
Fluoride	< 0.10 mg/L	<=1.5 MAC	Final
Iron (dissolved)	< 0.010 mg/L		Final
Iron (total)	0.013 mg/L	<=0.3 AO	Final
Lead (dissolved)	0.00149 mg/L		Final



# Laboratory Report

Report Name: 0041739\_FINAL\_WaterTrax\_25\_Sep\_20\_1334.txt

**Sample ID:** 0041739-01 (continued)  
**Water System:** Core Water System  
**Source:** PW 624 and PW 621 Wells  
**Facility:** PW 624 Well Pumphouse  
**Sampling Pt:** PW 624 Pumphouse Well 1 raw water (PW624-1-SR, DBA5)  
**Comment:** Generated by File Transfer  
**Sampled:** 04/22/2020 10:00

INORGANIC		Criteria & Type	Status
Lead (total)	0.00093 mg/L	<=0.005 MAC	Final
Lithium (dissolved)	0.00338 mg/L		Final
Lithium (total)	0.00336 mg/L		Final
Magnesium (dissolved)	13.8 mg/L		Final
Magnesium (total)	13.6 mg/L		Final
Manganese (dissolved)	0.0299 mg/L		Final
<b>* Manganese (total)</b>	<b>0.0722 mg/L</b>	<b>&lt;=0.02 AO</b>	<b>Final</b>
Mercury (dissolved)	< 0.000010 mg/L		Final
Mercury (total)	< 0.000010 mg/L	<=0.001 MAC	Final
Molybdenum (dissolved)	0.00207 mg/L		Final
Molybdenum (total)	0.00191 mg/L		Final
Nickel (dissolved)	0.00044 mg/L		Final
Nickel (total)	< 0.00040 mg/L		Final
Nitrate (as N)	0.012 mg/L		Final
Nitrate + Nitrite (as N)	0.0125 mg/L		Final
Nitrite (as N)	< 0.010 mg/L		Final
o-Phosphate (as P)	0.0105 mg/L		Final
Phosphorus (total dissolved)	< 0.050 mg/L		Final
Phosphorus (total)	< 0.050 mg/L		Final
Potassium (dissolved)	2.58 mg/L		Final
Potassium (total)	2.57 mg/L		Final
Selenium (dissolved)	< 0.00050 mg/L		Final
Selenium (total)	< 0.00050 mg/L	<=0.05 MAC	Final
Silicon (dissolved, as Si)	7.3 mg/L		Final
Silicon (total, as Si)	7.5 mg/L		Final
Silver (dissolved)	< 0.000050 mg/L		Final
Silver (total)	< 0.000050 mg/L		Final
Sodium (dissolved)	6.61 mg/L		Final
Sodium (total)	6.54 mg/L	<=200 AO	Final
Strontium (dissolved)	0.327 mg/L		Final
Strontium (total)	0.334 mg/L		Final
Sulfur (dissolved)	5.6 mg/L		Final
Sulfur (total)	6.0 mg/L		Final
Sulphate	14.6 mg/L	<=500 AO	Final
Tellurium (dissolved)	< 0.00050 mg/L		Final
Tellurium (total)	< 0.00050 mg/L		Final

# Laboratory Report

Report Name: 0041739\_FINAL\_WaterTrax\_25\_Sep\_20\_1334.txt

**Sample ID:** 0041739-01 (continued)  
**Water System:** Core Water System  
**Source:** PW 624 and PW 621 Wells  
**Facility:** PW 624 Well Pumphouse  
**Sampling Pt:** PW 624 Pumphouse Well 1 raw water (PW624-1-SR, DBA5)  
**Comment:** Generated by File Transfer  
**Sampled:** 04/22/2020 10:00

INORGANIC		Criteria & Type	Status
Thallium (dissolved)	< 0.000020 mg/L		Final
Thallium (total)	< 0.000020 mg/L		Final
Thorium (dissolved)	< 0.00010 mg/L		Final
Thorium (total)	< 0.00010 mg/L		Final
Tin (dissolved)	< 0.00020 mg/L		Final
Tin (total)	< 0.00020 mg/L		Final
Titanium (dissolved)	< 0.0050 mg/L		Final
Titanium (total)	< 0.0050 mg/L		Final
Tungsten (dissolved)	< 0.0010 mg/L		Final
Tungsten (total)	< 0.0010 mg/L		Final
Uranium (dissolved)	0.00178 mg/L		Final
Vanadium (dissolved)	0.0011 mg/L		Final
Vanadium (total)	0.0013 mg/L		Final
Zinc (dissolved)	0.0633 mg/L		Final
Zinc (total)	0.0356 mg/L	<=5 AO	Final
Zirconium (dissolved)	< 0.00010 mg/L		Final
Zirconium (total)	< 0.00010 mg/L		Final
MICROORGANISMS		Criteria & Type	Status
Escherichia coli / E. coli (counts)	< 1 CFU/100ml	<=0,OG Microbiological standard	Final
Fecal (thermal tolerant) Coliforms (counts)	< 1 CFU/100ml	<=0 Microbiological Standard	Final
Total Coliforms (counts)	< 1 CFU/100ml	<=0,OG User-Defined	Final
ORGANIC		Criteria & Type	Status
Adsorbable Organic Halides / AOX	21 ug/L		Final
Bromodichloromethane (dichlorobromomethane)	< 0.0010 mg/L	<=0.1 IMAC for TTHM expressed as a running annual average	Final
Bromoform	< 0.0010 mg/L	<=0.1 IMAC for TTHM expressed as a running annual average	Final
Chloroform	< 0.0010 mg/L	<=0.1 Standard for TTHM expressed as a running annual average	Final
Dibromochloromethane (Chlorodibromomethane)	< 0.0010 mg/L	<=0.1 IMAC for TTHM expressed as a running annual average	Final
Nitrogen (total)	< 0.0500 mg/L		Final
Total Kjeldahl Nitrogen / TKN	< 0.050 mg/L		Final





# Laboratory Report

Report Name: 0041739\_FINAL\_WaterTrax\_25\_Sep\_20\_1334.txt

**Sample ID:** 0041739-01 (continued)  
**Water System:** Core Water System  
**Source:** PW 624 and PW 621 Wells  
**Facility:** PW 624 Well Pumphouse  
**Sampling Pt:** PW 624 Pumphouse Well 1 raw water (PW624-1-SR, DBA5)  
**Comment:** Generated by File Transfer  
**Sampled:** 04/22/2020 10:00

ORGANIC		Criteria & Type	Status
Total Trihalomethanes / TTHM	< 0.00400 mg/L	<=0.1 IMAC based on running annual average	Final
PHYSICAL		Criteria & Type	Status
Alkalinity (bicarbonate, as CaCO3)	172 mg/L		Final
Alkalinity (carbonate, as CaCO3)	< 1.0 mg/L		Final
Alkalinity (hydroxide, as CaCO3)	< 1.0 mg/L		Final
Alkalinity (phenolphthalein, as CaCO3)	< 1.0 mg/L		Final
Alkalinity (total, as CaCO3)	172 mg/L		Final
Hardness (dissolved, as CaCO3)	158 mg/L		Final
Hardness (total, as CaCO3)	161 mg/L		Final
Total Suspended Solids / TSS	< 2.0 mg/L		Final
RADIONUCLIDES		Criteria & Type	Status
Uranium (total)	0.00189 mg/L	<=0.02 MAC	Final

### Result Legend

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no,  
TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment  
< means less than lower detection limit shown

> means greater than upper detection limit shown

« means detected & less than number shown

» means detected & greater than number shown

\* Indicates Criteria is exceeded