

# Laboratory Report

Exova

Report For: City of Prince George  
 Received: 04/16/2019 16:51  
 Report ID: 2392530  
 Report Name:

**Sample ID:** 1342208-1  
**Water System:** Core Water System  
**Source:** PW 605 Well  
**Facility:** PW 605 Well Pumphouse  
**Sampling Pt:** PW 605 Pumphouse treated water (PW605-2-EP, DBC0)  
**Comment:** DBC0 / PW 605-Raw Water (treated) / 6.2°C  
**Sampled:** 04/02/2019 09:00

INORGANIC		Criteria & Type	Status
Aluminum (total)	0.003 mg/L	<=0.1 Operational - Conventional	Final
Antimony (total)	0.00028 mg/L	<=0.006 MAC	Final
Arsenic (total)	0.0003 mg/L	Current Level	Final
Barium (total)	0.020 mg/L	<=1 MAC	Final
Beryllium (total)	< 0.00005 mg/L		Final
Bismuth (total)	0.0001 mg/L		Final
Boron (total)	0.007 mg/L	<=5 MAC	Final
Cadmium (total)	0.00002 mg/L	<=0.005 MAC	Final
Calcium (dissolved)	29 mg/L		Final
Calcium (total)	28 mg/L		Final
Chloride	5.35 mg/L	<=250 AO	Final
Chromium (total)	0.00014 mg/L	<=0.05 MAC	Final
Cobalt (total)	0.00002 mg/L		Final
Copper (total)	0.011 mg/L	<=1 AO	Final
Fluoride	0.06 mg/L	<=1.5 MAC	Final
Iron (total)	0.013 mg/L	<=0.3 AO	Final
Iron (total)	0.011 mg/L	<=0.3 AO	Final
Lead (total)	0.00009 mg/L	<=0.005 MAC	Final
Lithium (total)	0.0005 mg/L		Final
Magnesium (dissolved)	8.8 mg/L		Final
Magnesium (total)	8.4 mg/L		Final
Manganese (total)	0.013 mg/L	<=0.05 AO	Final
Manganese (total)	0.015 mg/L	<=0.05 AO	Final
Molybdenum (total)	0.0016 mg/L		Final
Nickel (total)	0.0005 mg/L		Final
Nitrate (as N)	0.18 mg/L		Final
Nitrite (as N)	< 0.01 mg/L		Final
o-Phosphate (dissolved, as P)	0.004 mg/L		Final
Potassium (dissolved)	1.3 mg/L		Final
Potassium (total)	1.3 mg/L		Final
Selenium (total)	0.0011 mg/L	<=0.05 MAC	Final



# Laboratory Report

Exova

Report Name:

**Sample ID:** 1342208-1 (continued)  
**Water System:** Core Water System  
**Source:** PW 605 Well  
**Facility:** PW 605 Well Pumphouse  
**Sampling Pt:** PW 605 Pumphouse treated water (PW605-2-EP, DBC0)  
**Comment:** DBC0 / PW 605-Raw Water (treated) / 6.2°C  
**Sampled:** 04/02/2019 09:00

INORGANIC		Criteria & Type		Status
Silicon (total, as Si)	4.6 mg/L			Final
Silver (total)	0.00036 mg/L			Final
Sodium (dissolved)	5.1 mg/L			Final
Sodium (total)	5.1 mg/L	<=200	AO	Final
Strontium (total)	0.12 mg/L			Final
Sulfur (total)	3.2 mg/L			Final
Sulphate	9.6 mg/L	<=500	AO	Final
Thallium (total)	0.00008 mg/L			Final
Tin (total)	< 0.0001 mg/L			Final
Titanium (total)	0.003 mg/L			Final
Vanadium (total)	0.00036 mg/L			Final
Zinc (total)	0.0031 mg/L	<=5	AO	Final
Zirconium (total)	0.0012 mg/L			Final

MICROORGANISMS		Criteria & Type		Status
Escherichia coli / E. coli (MPN)	< 1.0 MPN/100ml	<=0,P	Microbiological standard	Final
Fecal (thermal tolerant) Coliforms (counts)	< 1 CFU/100ml	<=0	Microbiological Standard	Final
Total Coliforms (MPN)	< 1.0 MPN/100ml	<=0,P	User-Defined	Final

ORGANIC		Criteria & Type		Status
Bromodichloromethane (dichlorobromomethane)	< 0.001 mg/L	<=0.1	IMAC for TTHM expressed as a running annual average	Final
Bromoform	< 0.001 mg/L	<=0.1	IMAC for TTHM expressed as a running annual average	Final
Chloroform	0.001 mg/L	<=0.1	Standard for TTHM expressed as a running annual average	Final
Dibromochloromethane (Chlorodibromomethane)	< 0.001 mg/L	<=0.1	IMAC for TTHM expressed as a running annual average	Final
Total Organic Carbon / TOC	2.5 mg/L			Final
Total Trihalomethanes / TTHM	0.001 mg/L	<=0.1	IMAC based on running annual average	Final

PHYSICAL		Criteria & Type		Status
Alkalinity (total, as CaCO3)	102 mg/L			Final
Bicarbonate (as HCO3)	125 mg/L			Final
Carbonate (as CO3)	< 6 mg/L			Final



Colour

< 5 TCU

<=15

AO

Final

# Laboratory Report

Exova

Report Name:

**Sample ID:** 1342208-1 (continued)  
**Water System:** Core Water System  
**Source:** PW 605 Well  
**Facility:** PW 605 Well Pumphouse  
**Sampling Pt:** PW 605 Pumphouse treated water (PW605-2-EP, DBC0)  
**Comment:** DBC0 / PW 605-Raw Water (treated) / 6.2°C  
**Sampled:** 04/02/2019 09:00

PHYSICAL		Criteria & Type		Status
Conductivity	232 uS/cm			Final
Hardness (total, as CaCO3)	110 mg/L			Final
Hydroxide (as OH)	< 5 mg/L			Final
pH	7.72		Current Level	Final
Total Dissolved Solids / TDS (computed)	135 mg/L			Final
Total Suspended Solids / TSS	< 2 mg/L			Final
Turbidity	< 0.05 NTU	<=5	User-Defined	Final
RADIONUCLIDES		Criteria & Type		Status
Uranium (total)	0.00029 mg/L	<=0.02	MAC	Final

### Result Legend

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no, TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment  
< means less than lower detection limit shown

> means greater than upper detection limit shown

« means detected & less than number shown

» means detected & greater than number shown

\* Indicates Criteria is exceeded