

# Laboratory Report

Exova

Report For: City of Prince George  
 Received: 10/24/2018 14:51  
 Report ID: 2331364  
 Report Name:

**Sample ID:** 1303882-1  
**Water System:** Core Water System  
**Source:** PW 605 Well  
**Facility:** PW 605 Well Pumphouse  
**Sampling Pt:** PW 605 Pumphouse treated water (PW605-2-EP, DBC0)  
**Comment:** DBC0 / PW 605-Raw Water (treated) / 5.4 °C  
**Sampled:** 10/09/2018 10:33

INORGANIC		Criteria & Type	Status
Aluminum (total)	0.005 mg/L	<=0.1 Operational - Conventional	Final
Antimony (total)	0.00015 mg/L	<=0.006 MAC	Final
Arsenic (total)	0.0003 mg/L	Current Level	Final
Barium (total)	0.021 mg/L	<=1 MAC	Final
Beryllium (total)	< 0.00005 mg/L		Final
Bismuth (total)	< 0.0001 mg/L		Final
Boron (total)	0.007 mg/L	<=5 MAC	Final
Cadmium (total)	0.00001 mg/L	<=0.005 MAC	Final
Calcium (dissolved)	27 mg/L		Final
Calcium (total)	28 mg/L		Final
Chloride	8.35 mg/L	<=250 AO	Final
Chromium (total)	< 0.00005 mg/L	<=0.05 MAC	Final
Cobalt (total)	0.00004 mg/L		Final
Copper (total)	0.050 mg/L	<=1 AO	Final
Fluoride	0.02 mg/L	<=1.5 MAC	Final
Iron (total)	0.014 mg/L	<=0.3 AO	Final
Iron (total)	< 0.004 mg/L	<=0.3 AO	Final
Lead (total)	0.00045 mg/L	<=0.01 MAC	Final
Lithium (total)	0.0007 mg/L		Final
Magnesium (dissolved)	8.6 mg/L		Final
Magnesium (total)	8.5 mg/L		Final
Manganese (total)	0.014 mg/L	<=0.05 AO	Final
Manganese (total)	0.015 mg/L	<=0.05 AO	Final
Molybdenum (total)	0.0016 mg/L		Final
Nickel (total)	0.0010 mg/L		Final
Nitrate (as N)	0.18 mg/L		Final
Nitrite (as N)	< 0.01 mg/L		Final
o-Phosphate (dissolved, as P)	< 0.002 mg/L		Final
Potassium (dissolved)	1.3 mg/L		Final
Potassium (total)	1.3 mg/L		Final
Selenium (total)	0.0010 mg/L	<=0.05 MAC	Final



# Laboratory Report

Exova

Report Name:

**Sample ID:** 1303882-1 (continued)  
**Water System:** Core Water System  
**Source:** PW 605 Well  
**Facility:** PW 605 Well Pumphouse  
**Sampling Pt:** PW 605 Pumphouse treated water (PW605-2-EP, DBC0)  
**Comment:** DBC0 / PW 605-Raw Water (treated) / 5.4 °C  
**Sampled:** 10/09/2018 10:33

INORGANIC		Criteria & Type		Status
Silicon (total, as Si)	4.7 mg/L			Final
Silver (total)	< 0.00001 mg/L			Final
Sodium (dissolved)	6.2 mg/L			Final
Sodium (total)	6.1 mg/L	<=200	AO	Final
Strontium (total)	0.13 mg/L			Final
Sulfur (total)	3.4 mg/L			Final
Sulphate	10.2 mg/L	<=500	AO	Final
Thallium (total)	< 0.00001 mg/L			Final
Tin (total)	< 0.0001 mg/L			Final
Titanium (total)	0.002 mg/L			Final
Uranium (total)	0.00031 mg/L	<=0.02	MAC	Final
Vanadium (total)	0.00033 mg/L			Final
Zinc (total)	0.0052 mg/L	<=5	AO	Final
Zirconium (total)	< 0.0001 mg/L			Final

MICROORGANISMS		Criteria & Type		Status
Escherichia coli / E. coli (MPN / PA)	< 1.0 MPN/100ml	<=0,P	Microbiological standard	Final
Fecal (thermal tolerant) Coliforms (counts)	< 1 CFU/100ml	<=0	Microbiological Standard	Final
Total Coliforms (MPN / PA)	< 1.0 MPN/100ml	<=0,P	User-Defined	Final

ORGANIC		Criteria & Type		Status
Bromodichloromethane	0.002 mg/L	<=0.1	IMAC for TTHM expressed as a running annual average	Final
Bromoform	< 0.001 mg/L	<=0.1	IMAC for TTHM expressed as a running annual average	Final
Chloroform	0.017 mg/L	<=0.1	Standard for TTHM expressed as a running annual average	Final
Dibromochloromethane	< 0.001 mg/L	<=0.1	IMAC for TTHM expressed as a running annual average	Final
Total Organic Carbon / TOC	2.2 mg/L			Final
Total Trihalomethanes / TTHM	0.019 mg/L	<=0.1	IMAC based on running annual average	Final

PHYSICAL		Criteria & Type		Status
Alkalinity (total, as CaCO3)	98 mg/L			Final
Bicarbonate (as HCO3)	120 mg/L			Final





# Laboratory Report

Exova

Report Name:

**Sample ID:** 1303882-1 (continued)  
**Water System:** Core Water System  
**Source:** PW 605 Well  
**Facility:** PW 605 Well Pumphouse  
**Sampling Pt:** PW 605 Pumphouse treated water (PW605-2-EP, DBC0)  
**Comment:** DBC0 / PW 605-Raw Water (treated) / 5.4 °C  
**Sampled:** 10/09/2018 10:33

PHYSICAL			Criteria & Type	Status
Colour	< 5	TCU	<=15 AO	Final
Conductivity	235	uS/cm		Final
Hardness (total, as CaCO3)	104	mg/L		Final
Hydroxide (as OH)	< 5	mg/L		Final
pH	7.68		Current Level	Final
Total Dissolved Solids / TDS (computed)	135	mg/L		Final
Total Suspended Solids / TSS	< 2.0	mg/L		Final
Turbidity	0.12	NTU	<=5 User-Defined	Final

### Result Legend

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no, TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment  
< means less than lower detection limit shown

> means greater than upper detection limit shown

« means detected & less than number shown

» means detected & greater than number shown

\* Indicates Criteria is exceeded