Report For: City of Prince George Received: 10/24/2018 14:51

Report ID: 2331371

Report Name:

Sample ID: 1303891-1

Water System: BCR Danson Industrial Water System

Source: PW 627 Well

Facility: PW 627 Well Pumphouse

Sampling Pt: PW 627 Pumphouse raw water (PW627-2-SR, DB94)

Comment: DB94 / PW627-Raw Water / 5.4°C

Sampled: 10/09/2018 11:30

INORGANIC			Criteria & Ty	pe	Status
Aluminum (total)	< 0.001	mg/L	<=0.1	Operational - Conventional	Final
Antimony (total)	0.00003	mg/L	<=0.006	MAC	Final
Arsenic (total)	0.0004	mg/L		Current Level	Final
Barium (total)	0.070	mg/L	<=1	MAC	Final
Beryllium (total)	< 0.00005	mg/L			Final
Bismuth (total)	< 0.0001	mg/L			Final
Boron (total)	0.005	mg/L	<=5	MAC	Final
Cadmium (total)	< 0.00001	mg/L	<=0.005	MAC	Final
Calcium (dissolved)	79	mg/L			Final
Calcium (total)	82	mg/L			Final
Chloride	16.5	mg/L	<=250	AO	Final
Chromium (total)	< 0.00005	mg/L	<=0.05	MAC	Final
Cobalt (total)	< 0.00002	mg/L			Final
Copper (total)	0.0028	mg/L	<=1	AO	Final
Fluoride	0.03	mg/L	<=1.5	MAC	Final
Iron (total)	0.049	mg/L	<=0.3	AO	Final
Iron (total)	0.044	mg/L	<=0.3	AO	Final
Lead (total)	0.00007	mg/L	<=0.01	MAC	Final
Lithium (total)	0.0044	mg/L			Final
Magnesium (dissolved)	23	mg/L			Final
Magnesium (total)	23	mg/L			Final
Manganese (total)	0.019	mg/L	<=0.05	AO	Final
Manganese (total)	0.022	mg/L	<=0.05	AO	Final
Molybdenum (total)	0.0011	mg/L			Final
Nickel (total)	< 0.0002	mg/L			Final
Nitrate (as N)	0.44	mg/L			Final
Nitrite (as N)	< 0.01	mg/L			Final
o-Phosphate (dissolved, as P)	0.007	mg/L			Final
Potassium (dissolved)	2.2	mg/L			Final
Potassium (total)	2.2	mg/L			Final
Selenium (total)	0.0025	mg/L	<=0.05	MAC	Final

Report Name:

Sample ID: 1303891-1 (continued)

Water System: BCR Danson Industrial Water System

Source: PW 627 Well

Facility: PW 627 Well Pumphouse

Sampling Pt: PW 627 Pumphouse raw water (PW627-2-SR, DB94)

Comment: DB94 / PW627-Raw Water / 5.4°C

Sampled: 10/09/2018 11:30

		Criteria & Ty	pe	Status
9.0	mg/L			Final
< 0.00001	mg/L			Final
7.9	mg/L			Final
8.4	mg/L	<=200	AO	Final
0.41	mg/L			Final
4.9	mg/L			Final
12.3	mg/L	<=500	AO	Final
< 0.00001	mg/L			Final
< 0.0001	mg/L			Final
0.007	mg/L			Final
0.0059	mg/L	<=0.02	MAC	Final
0.00038	mg/L			Final
0.0011	mg/L	<=5	AO	Final
< 0.0001	mg/L			Final
		Criteria & Type		Status
< 1.0	MPN/100ml	<=0,P	Microbiological standard	Final
< 1	CFU/100ml	<=0	Microbiological Standard	Final
< 1.0	MPN/100ml	<=0,P	User-Defined	Final
		Criteria & Ty	pe	Status
< 0.001	mg/L	<=0.1	IMAC for TTHM expressed as a running annual average	Final
< 0.001	mg/L	<=0.1	IMAC for TTHM expressed as a running annual average	Final
< 0.001	mg/L	<=0.1	Standard for TTHM expressed as a running annual average	Final d
< 0.001	mg/L	<=0.1	IMAC for TTHM expressed as a running annual average	Final
1.1	mg/L			Final
< 0.001	mg/L	<=0.1	IMAC based on running annual average	Final
		Criteria & Ty	ре	Status
282	mg/L	-		Final
	_			Final
				page 2 of 4
	< 0.00001	9.0 mg/L < 0.00001 mg/L 7.9 mg/L 8.4 mg/L 0.41 mg/L 4.9 mg/L 12.3 mg/L < 0.00001 mg/L 0.007 mg/L 0.0059 mg/L 0.00038 mg/L 0.0011 mg/L < 0.0001 mg/L < 1.0 MPN/100ml < 1 CFU/100ml < 1.0 MPN/100ml < 1.0 mg/L < 0.001 mg/L < 0.001 mg/L < 0.001 mg/L < 0.001 mg/L < 1.0 MPN/100ml	9.0 mg/L < 0.00001 mg/L 7.9 mg/L 8.4 mg/L 4.9 mg/L 12.3 mg/L < 0.0001 mg/L 0.007 mg/L 0.0059 mg/L 0.0011 mg/L < 0.0001 mg/L < 0.0001 mg/L < 1.0 MPN/100ml < 1 CFU/100ml < 1.0 MPN/100ml < 0.001 mg/L < 0.001 mg/L < 0.001 mg/L < 1.0 MPN/100ml < 20,P Criteria & Ty < 0.001 mg/L < 0.001 mg/L	 < 0.00001 mg/L 7.9 mg/L 8.4 mg/L 4.9 mg/L 4.0 mg/L 6.00001 mg/L 6.0001 mg/L 6.0007 mg/L 6.0003 mg/L 6.0001 mg/L 7.0 mg/L 8.0 mg/L<





Report Name:

Sample ID: 1303891-1 (continued)

Water System: BCR Danson Industrial Water System

Source: PW 627 Well

Facility: PW 627 Well Pumphouse

Sampling Pt: PW 627 Pumphouse raw water (PW627-2-SR, DB94)

Comment: DB94 / PW627-Raw Water / 5.4°C

Sampled: 10/09/2018 11:30

PHYSICAL			Criteria & T	уре	Status
Colour	< 5	TCU	<=15	AO	Final
Conductivity	582	uS/cm			Final
Hardness (total, as CaCO3)	290	mg/L			Final
Hydroxide (as OH)	< 5	mg/L			Final
рН	7.82			Current Level	Final
Total Dissolved Solids / TDS (computed)	338	mg/L			Final
Total Suspended Solids / TSS	< 2.000	mg/L			Final
Turbidity	0.13	NTU	<=5	User-Defined	Final

Result Legend

 $P\!\!=\!\!present,\,A\!\!=\!\!absent,\,PR\!\!=\!\!presumptive,\,ND\!\!=\!\!non\text{-}detect,\,\,OR\!\!=\!\!over\text{-}range,\,\,OG\!\!=\!\!overgrown,\,\,Y\!\!=\!\!yes,\,\,N\!\!=\!\!no,\,\,N$

TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

- < means less than lower detection limit shown
- > means greater than upper detection limit shown
- « means detected & less than number shown
- » means detected & greater than number shown
- * Indicates Criteria is exceeded

