Exova

Report For: City of Prince George Received: 07/17/2018 10:10

Report ID: 2270779

Report Name:

Sample ID: 1259555-1

Water System: BCR Danson Industrial Water System

Source: PW 627 Well

Facility: PW 627 Well Pumphouse

Sampling Pt: PW 627 Pumphouse raw water (PW627-2-SR, DB94)

Comment: DB94 / PW627-Raw Water / 7.1 °C

Sampled: 03/14/2018 12:20

INORGANIC			Criteria & Ty	pe	Status
Aluminum (total)	< 0.001	mg/L	<=0.1	Operational - Conventional	Final
Antimony (total)	0.00004	mg/L	<=0.006	MAC	Final
Arsenic (total)	0.0004	mg/L		Current Level	Final
Barium (total)	0.075	mg/L	<=1	MAC	Final
Beryllium (total)	< 0.00005	mg/L			Final
Bismuth (total)	< 0.0001	mg/L			Final
Boron (total)	0.009	mg/L	<=5	MAC	Final
Cadmium (total)	< 0.00001	mg/L	<=0.005	MAC	Final
Calcium (dissolved)	86	mg/L			Final
Calcium (total)	87	mg/L			Final
Chloride	17.7	mg/L	<=250	AO	Final
Chromium (total)	< 0.00005	mg/L	<=0.05	MAC	Final
Cobalt (total)	< 0.00002	mg/L			Final
Copper (total)	0.0041	mg/L	<=1	AO	Final
Fluoride	0.04	mg/L	<=1.5	MAC	Final
Iron (total)	0.039	mg/L	<=0.3	AO	Final
Iron (total)	0.042	mg/L	<=0.3	AO	Final
Lead (total)	0.000097	mg/L	<=0.01	MAC	Final
Lithium (total)	0.0057	mg/L			Final
Magnesium (dissolved)	25	mg/L			Final
Magnesium (total)	24	mg/L			Final
Manganese (total)	0.021	mg/L	<=0.05	AO	Final
Manganese (total)	0.022	mg/L	<=0.05	AO	Final
Molybdenum (total)	0.0014	mg/L			Final
Nickel (total)	0.0003	mg/L			Final
Nitrate (as N)	0.40	mg/L			Final
Nitrite (as N)	< 0.01	mg/L			Final
o-Phosphate (dissolved, as P)	0.006	mg/L			Final
Potassium (dissolved)	2.3	mg/L			Final
Potassium (total)	2.4	mg/L			Final
Selenium (total)	0.0026	mg/L	<=0.05	MAC	Final

Report created on 07/19/2018 9:00:14PM

Report Name:

Sample ID: 1259555-1 (continued)

Water System: BCR Danson Industrial Water System

Source: PW 627 Well

Facility: PW 627 Well Pumphouse

Sampling Pt: PW 627 Pumphouse raw water (PW627-2-SR, DB94)

Comment: DB94 / PW627-Raw Water / 7.1 °C

Sampled: 03/14/2018 12:20

INODOANIO			Outrada 6 To		01-1
INORGANIC	0.0	/I	Criteria & Ty	pe	Status
Silicon (total, as Si)		mg/L			Final Final
Silver (total) Sodium (dissolved)	< 0.00001	-			Final
		mg/L mg/L	200	AO	Final
Sodium (total) Strontium (total)		mg/L	<=200	AU	Final
Sulfur (total)		mg/L			Final
Sulphate		mg/L	<=500	AO	Final
Thallium (total)	< 0.00001	J	<=500	AO	Final
Tin (total)	< 0.00001	•			Final
Titanium (total)	0.0001	•			Final
Uranium (total)	0.0093	•	<=0.02	MAC	Final
Vanadium (total)	0.0001	•	<=0.02	WAC	Final
Zinc (total)	0.00034	•	<=5	AO	Final
Ziric (total) Zirconium (total)	< 0.0024	•	_ 5	70	Final
, ,	< 0.0001	mg/L			
MICROORGANISMS			Criteria & Ty	pe	Status
Escherichia coli / E. coli (MPN / PA)	< 1.0	MPN/100ml	<=0,P	Microbiological standard	Final
Fecal Coliforms (counts)	< 1	CFU/100ml	<=0	Microbiological Standard	Final
Total Coliforms (MPN / PA)	< 1.0	MPN/100ml	<=0,P	User-Defined	Final
ORGANIC			Criteria & Ty	pe	Status
Bromodichloromethane	< 0.001	mg/L	<=0.1	IMAC for TTHM expressed as a running annual average	Final
Bromoform	< 0.001	mg/L	<=0.1	IMAC for TTHM expressed as a running annual average	Final
Chloroform	< 0.001	mg/L	<=0.1	Standard for TTHM expressed as a running annual average	Final d
Dibromochloromethane	< 0.001	mg/L	<=0.1	IMAC for TTHM expressed as a running annual average	Final
Total Organic Carbon / TOC	1.4	mg/L			Final
Total Trihalomethanes / TTHM	< 0.001	mg/L	<=0.1	IMAC based on running annual average	Final
PHYSICAL			Criteria & Ty	ре	Status
Alkalinity (total, as CaCO3)	285	mg/L	-		Final
Bicarbonate (as HCO3)		mg/L			Final
Report created on 07/19/2018 9:00:14PM					page 2 of





Report Name:

Sample ID: 1259555-1 (continued)

Water System: BCR Danson Industrial Water System

Source: PW 627 Well

Facility: PW 627 Well Pumphouse

Sampling Pt: PW 627 Pumphouse raw water (PW627-2-SR, DB94)

Comment: DB94 / PW627-Raw Water / 7.1 °C

Sampled: 03/14/2018 12:20

PHYSICAL		Criteria & Type		Status	
Colour	< 5	TCU	<=15	AO	Final
Conductivity	604	uS/cm			Final
Hardness (total, as CaCO3)	320	mg/L			Final
Hydroxide (as OH)	< 5	mg/L			Final
рН	7.75			Current Level	Final
Total Dissolved Solids / TDS (computed)	349	mg/L			Final
Total Suspended Solids / TSS	< 2.000	mg/L			Final
Turbidity	0.26	NTU	<=5	User-Defined	Final

Result Legend

TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

- < means less than lower detection limit shown
- > means greater than upper detection limit shown
- « means detected & less than number shown
- » means detected & greater than number shown
- * Indicates Criteria is exceeded

