**Exova** 

Report For: City of Prince George Received: 07/17/2018 10:11

Report ID: 2270819

Report Name:

Sample ID: 1259582-1

Water System: Upper Hart Water System

Source: PW 660 WELL

Facility: PW 660 Well Pumphouse

Sampling Pt: PW-660 Pumphouse Raw Water (PW660-1-SR, 14C95)

Comment: 14C95 / PW660-Raw Water / 6.9°C

Sampled: 03/14/2018 09:30

INORGANIC		Criteria & 1	Criteria & Type		
Aluminum (total)	< 0.001	mg/L	<=0.1	Operational - Conventional	Final
Antimony (total)	0.00015	mg/L	<=0.006	MAC	Final
Arsenic (total)	0.0001	mg/L		Current Level	Final
Barium (total)	0.027	mg/L	<=1	MAC	Final
Beryllium (total)	< 0.00005	mg/L			Final
Bismuth (total)	< 0.0001	mg/L			Final
Boron (total)	0.004	mg/L	<=5	MAC	Final
Cadmium (total)	< 0.00001	mg/L	<=0.005	MAC	Final
Calcium (dissolved)	24	mg/L			Final
Calcium (total)	25	mg/L			Final
Chloride	5.04	mg/L	<=250	AO	Final
Chromium (total)	0.00005	mg/L	<=0.05	MAC	Final
Cobalt (total)	< 0.00002	mg/L			Final
Copper (total)	0.041	mg/L	<=1	AO	Final
Fluoride	0.03	mg/L	<=1.5	MAC	Final
Iron (total)	0.005	mg/L	<=0.3	AO	Final
Iron (total)	0.008	mg/L	<=0.3	AO	Final
Lead (total)	0.0029	mg/L	<=0.01	MAC	Final
Lithium (total)	< 0.0005	mg/L			Final
Magnesium (dissolved)	6.6	mg/L			Final
Magnesium (total)	6.6	mg/L			Final
Manganese (total)	0.001	mg/L	<=0.05	AO	Final
Manganese (total)	0.001	mg/L	<=0.05	AO	Final
Molybdenum (total)	0.0017	mg/L			Final
Nickel (total)	0.0012	mg/L			Final
Nitrate (as N)	0.06	mg/L			Final
Nitrite (as N)	< 0.01	mg/L			Final
o-Phosphate (dissolved, as P)	< 0.002	mg/L			Final
Potassium (dissolved)	0.97	mg/L			Final
Potassium (total)	1.1	mg/L			Final
Selenium (total)	0.0007	mg/L	<=0.05	MAC	Final

Report Name:

Sample ID: 1259582-1 (continued)
Water System: Upper Hart Water System

Source: PW 660 WELL

Facility: PW 660 Well Pumphouse

Sampling Pt: PW-660 Pumphouse Raw Water (PW660-1-SR, 14C95)

Comment: 14C95 / PW660-Raw Water / 6.9°C

Sampled: 03/14/2018 09:30

		Criteria & Ty	ре	Status
4.4	mg/L			Final
0.00006	mg/L			Final
4.1	mg/L			Final
4.3	mg/L	<=200	AO	Final
0.11	mg/L			Final
2.8	mg/L			Final
7.8	mg/L	<=500	AO	Final
< 0.00001	mg/L			Final
0.0003	mg/L			Final
0.003	mg/L			Final
0.00016	mg/L	<=0.02	MAC	Final
0.00026	mg/L			Final
0.0077	mg/L	<=5	AO	Final
< 0.0001	mg/L			Final
		Criteria & Type		Status
< 1.0	MPN/100ml	<=0,P	Microbiological standard	Final
< 1	CFU/100ml	<=0	Microbiological Standard	Final
< 1.0	MPN/100ml	<=0,P	User-Defined	Final
		Criteria & Type		Status
< 0.001	mg/L	<=0.1	IMAC for TTHM expressed as a running annual average	Final
< 0.001	mg/L	<=0.1	IMAC for TTHM expressed as a running annual average	Final
0.006	mg/L	<=0.1	Standard for TTHM expressed as a running annual average	Final d
< 0.001	mg/L	<=0.1	IMAC for TTHM expressed as a running annual average	Final
2.3	mg/L			Final
0.006	mg/L	<=0.1	IMAC based on running annual average	Final
		Criteria & Ty	pe	Status
78	mg/L			Final
	mg/L mg/L			Final Final
	0.00006 4.1 4.3 0.11 2.8 7.8 < 0.00001 0.0003 0.00016 0.00026 0.0077 < 0.0001 < 1.0 < 1 < 1.0 < 0.001	4.4 mg/L 0.00006 mg/L 4.1 mg/L 4.3 mg/L 0.11 mg/L 2.8 mg/L 7.8 mg/L 0.0003 mg/L 0.0003 mg/L 0.00016 mg/L 0.00026 mg/L 0.00077 mg/L < 0.0001 mg/L < 1.0 MPN/100ml < 1 CFU/100ml < 1.0 MPN/100ml < 1.0 MPN/100ml < 0.001 mg/L  0.001 mg/L  2.3 mg/L 0.006 mg/L 0.006 mg/L	4.4 mg/L 0.00006 mg/L 4.1 mg/L 4.3 mg/L 2.8 mg/L 7.8 mg/L 0.0001 mg/L 0.0003 mg/L 0.0003 mg/L 0.00016 mg/L 0.00077 mg/L < 0.0001 mg/L  < 1.0 MPN/100ml < 20,P  Criteria & Tyl < 0.001 mg/L  < 0.001 mg/L	0.00006 mg/L 4.1 mg/L 4.3 mg/L 4.3 mg/L 2.8 mg/L 7.8 mg/L 0.0001 mg/L 0.0003 mg/L 0.0003 mg/L 0.00016 mg/L 0.00077 mg/L 0.00077 mg/L 0.00010 mg/L 0.00010 mg/L 0.00010 mg/L 0.00070 mg/L 0.00010 mg/L 0





Report Name:

Sample ID: 1259582-1 (continued)
Water System: Upper Hart Water System

Source: PW 660 WELL

Facility: PW 660 Well Pumphouse

Sampling Pt: PW-660 Pumphouse Raw Water (PW660-1-SR, 14C95)

Comment: 14C95 / PW660-Raw Water / 6.9°C

Sampled: 03/14/2018 09:30

PHYSICAL			Criteria & Type		Status
Colour	< 5	TCU	<=15	AO	Final
Conductivity	185	uS/cm			Final
Hardness (total, as CaCO3)	88	mg/L			Final
Hydroxide (as OH)	< 5	mg/L			Final
рН	7.47			Current Level	Final
Total Dissolved Solids / TDS (computed)	107	mg/L			Final
Total Suspended Solids / TSS	< 2.000	mg/L			Final
Turbidity	0.09	NTU	<=5	<b>User-Defined</b>	Final

## Result Legend

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no, TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

- < means less than lower detection limit shown
- > means greater than upper detection limit shown
- « means detected & less than number shown
- » means detected & greater than number shown

<sup>\*</sup> Indicates Criteria is exceeded

